

ADDENDUM NO.3

Wright Road Water Main Replacement
Project No. 21DPW01
Ayer DPW

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents; any verbal discussions or responses are hereby declared null and void.

Sealed Bids for the General Contract will be received from General Contractors for the Wright Road Water Main Replacement Project at the Ayer DPW Office, 25 Brook Street, Ayer, MA 01432 until 2:00 PM on Thursday, March 4, 2021 and at that time and place bids will be publicly opened and read aloud.

Bidder shall acknowledge receipt of this addendum on the Form for General Bid.

QUESTIONS

1. Since addendum #1 allows the proposed water main to be shifted to avoid conflict with the existing – will item #7 for temporary water be removed?
If not, is there any purpose to the item?

DPW Response:

The expectation is to locate the proposed water main in the same trench as much as possible and only relocate if required. Per Addenda No. 1, at least a portion of the pipe has been field confirmed as cast iron which would not have to be disposed of in a special manner like asbestos cement pipe.