

ADDENDUM NO.1

Main and Central Pump Station Valve Replacement Supplies  
Project No. 22DPW06  
Ayer DPW

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents; any verbal discussions or responses are hereby declared null and void.

Sealed Bids will be received for the Main and Central Pump Station valve Replacement Supplies at the Ayer DPW Office, 25 Brook Street, Ayer, MA 01432 until 1:00 PM on Thursday, February 3, 2022 and at that time and place bids will be publicly opened and read aloud. Per the Governor's Order to support the Commonwealth's response to the coronavirus, **the bid opening will be closed to the public and live streamed**. For access to the live stream, please email Dan Van Schalkwyk at [dvanschalkwyk@ayer.ma.us](mailto:dvanschalkwyk@ayer.ma.us)

**Bidder shall acknowledge receipt of this addendum on the Bid Price Form.**

PART 2 - SCOPE OF SERVICES or PRODUCT SPECIFICATIONS

1. Section 2.3.1.A. Manufacturers –
  - a) In Number 2., remove “Hilton Model H 200-SC, SCV” and replace with “DeZURIK Model KGC-ES”.
2. Section 2.3.1.B.3 Body –
  - a) Remove “c. V Port knife gate valves (VPKGV) include a 45 degree V-port fully seal welded in place of the same material as the body.” in its entirety.
3. Section 2.3.1.B.7 Seats –
  - b) Remove “a. Double seated” in its entirety.
4. Section 2.3.1.C Materials –
  - a) Remove “1. Sleeve: Buna-N” and “5. Lining: Elastomer suitable for process fluid.” in their entirety.
5. Section 2.4.1.A Manufacturers –
  - a) Add “DeZURIK Model CVS250” to line 1.
6. Section 2.4.1.C Materials –
  - a) Ductile iron shall be included as a material for body and disc.
  - b) Seat material shall include 316SS for 12” and 304SS for 16”.
  - c) Cover hardware shall include 304SS.