

ADDENDUM NO.1

Main St Street Light Improvements 2020t
Project No. 20DPW06
Ayer DPW

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents; any verbal discussions or responses are hereby declared null and void.

Sealed Bids for the General Contract will be received from General Contractors for the Main St Street Light Improvements 2020 Project at the Ayer DPW Office, 25 Brook Street, Ayer, MA 01432 until 1:00 PM on Friday December 6, 2019 and at that time and place bids will be publicly opened and read aloud.

Bidder shall acknowledge receipt of this addendum on the Form for General Bid.

SPECIFICATIONS

1. 00300 Form of General Bid, Page 00300-3 second paragraph – change to read “Work will be substantially complete within 160 calendar days after the date when the Contract Time commences to run provided the General Conditions and completed and ready for final payment within 175 calendar days after the date when the Contract Time commences to run.”
2. 00510 Agreement – Change 4.01 Contract Time to read “A. All time limits for Milestones, if any, Substantial Completion, and completion and readiness for final payment as stated in the Contract Documents are of the essence of the Contract. Work will be substantially complete within **160 calendar days** after the date when the Contract Time commences to run provided the General Conditions and completed and ready for final payment within **175 calendar days** after the date when the Contract Time commences to run.”
3. 265600 Street Lighting System and Appendix A Detail – Detail specifies King Luminaire fixture and Section 265600 specifies Sternberg fixture. Recent Town Street Light replacements have been King Luminaire fixture. Contractor may bid on either or an approved equal.
4. Section 265600 Paragraph 2.04 B – all poles shall include GFCI Receptacle, two banner arms and one flag pole bracket. Banner arms (Pelco SH-3530) and brackets (Pelco SH-3540) shall match existing Town fixtures.