


DEPARTMENT OF PUBLIC WORKS

Mark L. Wetzel, P.E., Superintendent
Daniel Van Schalkwyk, Town Engineer
Pamela J. Martin, Business Manager



25 BROOK STREET
AYER, MASSACHUSETTS 01432
T: (978) 772-8240
F: (978) 772-8244

MONTHLY REPORT April, 2016

Below is a summary of the Ayer DPW's operations for the month of April. In addition to the items below, there are many ongoing projects in various stages that the DPW staff are involved with. If additional detail or information is needed, please let us know.

Engineering and Administration

- Implement Maintenance Edge for WWTP, Spec Pond WTP and Grove Pond WTP
- Working on GIS mapping and condition assessments of drainage and sewer system
- Active involvement in Comprehensive Plan Committee
- Opened bids for West Main Street Pumping Station
- Prepared and submitted request for Complete Streets Planning Study to MassDOT
- Held design team Kick-off meeting for Ayer Dog Park
- Completing the design of Water Division Garage
- Working on bid documents for Fuel Station Canopy
- Construction coordination for Pingry Hill Water Tank
- Received bids for Pleasant Street CDBG grant improvement project
- Received bids for 2016 through 2018 Road Paving Spec
- Designed a received bids for Installation off Cellular RTUS for Wastewater Pumping Station
- Managed meter upgrade project including scheduling and computer account changes
- Quarterly water and sewer bills were prepared and sent out for 3 routes
- Reviewed and responded to questions and issues related to water and sewer bills
- Reviewed several subdivision / site plans for the Planning Board
- Processed and approved Road Opening Permits, Trench Permits and Water & Sewer Connection Permits

Highway / Stormwater Division

- Repaired pot holes and shoulders throughout town
- Installed new signs at various locations in town
- Completed spring street sweeping throughout Town
- Repaired 4 catch basins
- Mowed Police Station, Town Hall, Rotary, Sandy Pond School and other areas in Town
- Winterized plows, sanders and other snow/ice related equipment
- Video inspections of Devenscrest, Washington Street and Pleasant Street drains
- Performed beaver dam debris removal at the usual locations
- Repairing street sweep and mowing equipment
- DPW garage / facility maintenance
- Equipment and vehicle maintenance
- Trash and recycling pickup at numerous locations in town

- Completed DIGSAFE mark-outs

Water Division

- Began construction of East Main Street Water & Sewer Improvements
- Bagan Spring flushing
- Added data to H2O Water Reporting software and **submitted** reports to MADEP
- Maintenance of chemical feed systems at Grove Pond WTP
- Maintenance of chemical feed systems at Spec Pond WTP
- Completed alarm upgrades at Spec Pond WTP
- Continued radio water meter installations throughout Town
- Completed required DEP monthly coliform and chlorine sampling
- Completed meter readings and assisted customers with leak evaluations and dirty water issues
- Completed DIGSAFE mark-outs
- Normal water treatment duties including daily testing and reports, chemical adjustments, equipment maintenance

SUMMARY OPERATIONS REPORT FOR AYER DPW WATER DIVISION

Month/Year: 2016-04-01 To: 2016-04-30

PWS NO.: 2019000

Submitted By:

| Detail/Description | Values | | | | | |
|---------------------------|--------------------------|--------------|-------------------|---------|-------------|-----------|
| Pump and Flow Information | Total | Average | Maximum | Minimum | Days | Hours |
| WTFGP - Backwash | 3,859,000 | 128,633 | 195,000 | 0 | 30 | 0.00 |
| WTFGP - Raw Water | 24,312,000 | 810,400 | 1,389,000 | 61,000 | 30 | 0.00 |
| WTFSP - Raw Water | 14,446,000 | 481,533 | 1,133,000 | 0 | 30 | 0.00 |
| Chemical Feed Information | Volume/Weight | Pounds | Avg Dosage (mg/L) | | | |
| KMnO4 - WTFGP | 902.00 | 216.48 | 1.17 | | | |
| Water Quality Information | Chlorine Analyzer (Free) | Iron (Total) | Manganese (Total) | pH | pH Analyzer | Turbidity |
| WTFGP - Raw Water | | | | | 7.469 | |
| WTFGP - Finished Water | 0.293 | 0.018 | 0.031 | | 7.148 | 0.045 |

Wastewater Division

- All NEPS permit requirements were in compliance for the month of March
- Total flow for the treatment plant was 46.9 million gallons with an avg. of 1.52 mgd
- Contractor hauled 13 loads of sludge.
- Installed flow metering devices in 6 locations for I/I analysis
- Implemented Mobile 311 into daily Pumping Station maintenance
- Implemented Maintenance Edge into WWTP maintenance work orders
- Working with CDM-Smith on WWTP asset management study (DEP Grant)
- Completed Green Communities META Grant for WW pumping operations
- Performed mechanical maintenance on two pump stations, including pulling pumps and inspecting bearings and seals, plus replacing vacuum lines and cleaning or replacing globes.
- Washed down secondary clarifiers and cleaned UV system.\

DPW April 2016 Monthly Report

- Jetting and cleaning of sewer blockage at various locations in town
- Performed daily inspections of wastewater pumping stations
- Performed daily operations, laboratory testing and reporting for WWTP
- Completed DIGSAFE mark-outs
- Completed and **submitted** Monthly Operations Report for DEP and EPA

Solid Waste Division

- Normal transfer station operations including site clean-up, organization and monthly reports
- Leaf hauling to brush dump / compost area off Bishop Road
- Coordinated solid waste / recycling disposal including waste oil, scrap metals, textiles

| Location | | Work Type | Flagged By | Modified Date | Description | Comments |
|----------|--------------------------|--------------------------------------|-----------------------|-----------------|---|--|
| | Brook St | Routine Maintenance Work | djaspersen@ayer.ma.us | 2016-4-29 13:20 | Sanders | Bruce Wally & Mike W are doing the final cleaning and lubing of the Sanders for summer storage. |
| 0 | Town Roads | Misc Street Maintenance | djaspersen@ayer.ma.us | 2016-4-29 10:55 | | Doug Wally Bruce Mike F and Mike W repaired 2 home owner driveways that were damaged from plowing and hot topped the drainage Repair trench on Grove St and patched a handful of pot holes on Williams St and Mountain Ave. |
| | Pleasant St & Howard St | Repair Broken Sign | djaspersen@ayer.ma.us | 2016-4-29 10:49 | R&R Stop Sign | Bruce and Mike F replaced damaged Stop Sign on Pleasant & Howard St |
| 0 | Town Lawns | Mowing | djaspersen@ayer.ma.us | 2016-4-29 10:42 | | Bruce Mike F and Mike W are out cutting Town Hall Ayer PD and Rail Trail lawns today. Doug Bruce Mike W and Mike F cut the Rotary and Little Red School House lawns. |
| 0 | Main St | Main St Trash | djaspersen@ayer.ma.us | 2016-4-29 10:42 | | Mike F did Main St Trash and Town Hall and DPW |
| 32 | Deer Run | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-29 10:31 | mark out for Home owner | planting trees |
| 25 | Brook St | Street Sweeping | djaspersen@ayer.ma.us | 2016-4-29 10:44 | Friday Main St Sweeping | Bruce is sweeping main st |
| 3 | Third St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 13:37 | mark out Grid | installing relay gas service |
| | East St & Fletcher St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 13:37 | mark out Grid | installing relay gas service |
| 15 | Old Farm Way | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 13:37 | mark out | install patio & walkway |
| 32 | Calvin St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 13:37 | mark out | install new lawn and shrubs |
| 59 | Shirley St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 13:37 | mark out | installing deck |
| | West Main St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 13:37 | mark out Devens | Fixing and paving trench |
| | Groton School Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 13:37 | mark out Grid | install ground rod |
| 2 | Madigan Ln | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-29 10:44 | mark out | R & R Driveway |
| 35 | Quail Run | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out | sprinkler system |
| 97 | Holly Ridge | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out | storm water drainage |
| 10 | Apple blossom | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out | sprinkler system |
| 28 | Fletcher St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out for home owner | install trees |
| 15 | Maple St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out for Home owner | fence install |
| | West Main & Grant Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out | Building Obstacle Course |
| 34 | Pearl St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out | trees and new gas line |
| 5 | Nashua St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out for Home owner | tree planting |
| 3 | Madigan Lane | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-28 12:55 | mark out | R & R Driveway |
| 98 | Holly Ridge Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-27 14:18 | mark out for Home owner | planting trees |
| | | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-27 14:18 | mark out for Grid | |
| | West Main St & Barnum R | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-27 14:18 | mark out | demo sidewalks |
| 33 | Nashua St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-27 14:18 | mark out for Home owner | stump grinding |
| | | | | | | replace driveway |
| 32 | Williams St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-27 14:18 | mark out | |
| 9 | Mark St | Roadway Ice Operations | djaspersen@ayer.ma.us | 2016-4-28 12:55 | Plow Damage ? | I don't really see what home owner is talking about? |
| 25 | Brook St | Misc Special Event | mwetzel@ayer.ma.us | 2016-4-28 12:55 | | Please wash and wax the Office men's room floor and clean the toilet bowl |
| | | | | | | Got ahold of Sal from Sam's Catch Basin Cleaning he told me he could clean are catch basins again this year for under 10,000.00 grand. |
| 25 | Brook St | Catch Basin Clean Out | djaspersen@ayer.ma.us | 2016-4-28 12:55 | Catch Basin Cleaning Spring 2016 | |
| 25 | Brook St | Main St Trash | djaspersen@ayer.ma.us | 2016-4-25 06:59 | | Mike F and Dave M are doing Main St Trash Town Hall trash this morning. |
| | | | | | | Paving inspection of storm water catch basins. We started on the basins head towards the Main St South bound side. Basin #1 across from Page Hill Top School has an out fall behind houses it's a clay pipe 8 to 10 inch looks a little rough inside of basin but jetted out good and has good flow. Basin #2 the out fall side the jetted made it roughly 5 ft the pipe is old aluminum corrugated pipe it is in bad shape from what I can see of it the camera truck will tell us more. |
| | Washington Street | Complaint/Investigation - Stormwater | djaspersen@ayer.ma.us | 2016-4-28 12:55 | | |
| 0 | Sandy Pond Road | Dead Animal Removal | djaspersen@ayer.ma.us | 2016-4-28 12:55 | | Bruce & Doug picked up dead Shunk from middle of Sandy Pond Rd |
| 6 | Mountain Ave | Pavement Repair | djaspersen@ayer.ma.us | 2016-4-28 12:55 | Winter Driveway Plow Damage. | Repair driveway edge from plow damage |
| | | | | | | Calvin St Started at the west end basins #1 & #2 flow into trunk drain #1 18 inch concert pipe. All castings are prefabs. Cleaned out fall #1 out but needs more cleaning at out fall end brush etc. Basins #3 & #4 trunk drain #2 jetted and cleaned. camera looks great. Basins #5 & #6 trunk drain #3 jetted and cleaned. camera looks great. Basins #7 & #8 trunk drain #4 jetted and cleaned. camera looks great. Basins #9 & #10 trunk drain #5 jetted and cleaned. camera looks great. Down at the intersection at Blueberry Circle & Calvin St trunk drain #6 basin #11 & #12 off of Blueberry corners jetted and cleaned and camera. |
| 0 | Calvin St | Outfall Inspection | djaspersen@ayer.ma.us | 2016-4-22 08:04 | Calvin St Pre Paving Drainage Inspections | |
| 115 | Washington St | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-21 07:42 | Digsafe | Bryan marked the sewer line in the street. Gas leak repair |
| | Church St/East Main St | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-21 07:40 | Digsafe | Bryan marked entire street from Church St to East Main St. Gas leak repair |
| | Faulkner St Barnum rd | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-21 07:38 | Digsafe | Bryan marked entire street from East Main St to Faulkner St. Installing water main and services |
| | | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-21 07:01 | daily lab | batrnum rd |

| | | | | | |
|-----|---|--------------------------------------|-----------------------|-----------------|---|
| | | | | | We have a camera and jetting crew coming in today to start cleaning and camera drainage pipes on Willard St were we have drainage problems before we chip seal the road we are also doing Myrick St. |
| 99 | Willard Street Drainage. | Complaint/Investigation - Stormwater | djaspersen@ayer.ma.us | 2016-4-28 12:55 | Drainage cleaning |
| 120 | Barnum Rd | Grounds Maintenance - Water | rlinde@ayer.ma.us | 2016-4-21 13:32 | Grounds |
| | Willard St | Final Read | rlinde@ayer.ma.us | 2016-4-21 13:27 | final read |
| 16 | Grove St | Complaint/Investigation - Water | rlinde@ayer.ma.us | 2016-4-21 07:05 | dirty water |
| | | | | | MassDot came out and opened up the beaver Dam on Littleton Rd on the Town of Littleton's end the water is flowing nicely. |
| 0 | Littleton Rd-2A | Culvert/Swale Cleaning | djaspersen@ayer.ma.us | 2016-4-25 06:59 | |
| | | | | | Bryan C responded to a call from the homeowner at 5 Grovesner St who said he had slow drainage. Bryan used the metal detector to locate the clean out on the property which was buried under 8" of soil, he then opened it and showed the homeowner there was no backup in the cleanout. Bryan also opened the manhole in the street which was also flowing good and both Bryan and the homeowner agreed the problem was in between the house and the clean out. The homeowner asked Bryan if the town was responsible for the repairs and Bryan explained to him that the town is only responsible from the clean out to the street and told the homeowner he would have to contact a licensed plumber or sewer service repair contractor and they could further assist him. |
| 5 | Grovesner St | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-20 07:52 | Resident called slow drainage |
| | Fletcher St/ Pine St | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-20 07:38 | Digsafe |
| 126 | Haymeadow Ln | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-20 07:36 | Digsafe |
| 65 | Westford Rd | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-20 07:35 | Digsafe |
| 39 | Fletcher St | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-20 07:33 | Digsafe |
| | Snake Hill Rd | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-20 07:32 | Digsafe |
| | | | | | Install water main and services |
| 0 | Shaker Rd Culvert | Culvert/Swale Cleaning | djaspersen@ayer.ma.us | 2016-4-20 09:35 | Beaver Dam Removal |
| | | | | | Had to remove Beaver Dam from Shaker Rd culvert this morning they are back in full action. |
| 25 | Brook St | Misc Vehicle Work | djaspersen@ayer.ma.us | 2016-4-28 12:55 | Dump Truck Tail Gate Rack |
| | | | | | Wally is starting the welding and build of a tail gate rack for the dump truck tail gates that is need for storing dump truck tail gate why Sanders are in trucks over the winter months. |
| 25 | Brook St | Misc Debris Removal | djaspersen@ayer.ma.us | 2016-4-20 13:59 | |
| | | | | | Bruce will be with Ayer High School kids picking up trash from town main roads , road sides again today. |
| 25 | Brook St | Misc Special Event | djaspersen@ayer.ma.us | 2016-4-20 14:00 | |
| | | | | | Mike W is taking Mike F for round 2 of his CDL test today Fail test |
| 91 | Littleton Rd Blue Northern Culvert/Swale Cleaning | | djaspersen@ayer.ma.us | 2016-4-20 06:44 | Beaver Problem On Going |
| | | | | | Pulling out beaver Dam behind gun shop again to keep the Brook open and flowing. |
| 25 | Brook St | Street Sweeping | djaspersen@ayer.ma.us | 2016-4-19 12:30 | Mains round 2 spring sweeping |
| | | | | | All Main Roads are being redone for round 2 of Mains for spring sweeping cleanup Mike F & Dave M |
| 25 | Brook St | Misc Debris Removal | djaspersen@ayer.ma.us | 2016-4-19 12:30 | |
| | | | | | Bruce is working with a High School kid picking up trash on West Main St today |
| 108 | West Main St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | dig safe mark out |
| 1 | Nemco Way | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | dig safe mark out |
| 65 | Westford Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | dig safe mark out gas Grid |
| 126 | Hay Meadow Lane | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | dig safe mark out |
| | | | | | install lawn sprinklers |
| | | | | | dig safe mark out for Gas Grid |
| | Church St & Old East Main | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | Grid |
| 115 | Washington St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | dig safe mark out for Grid |
| 108 | W Main St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | dig safe mark out |
| | | | | | There are 2 dig safes for the same house they are both marked out |
| 39 | Fletcher St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | mark out for Grid |
| | | | | | installing new section of Railroad Tracks |
| 22 | Tannery St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | Take chemical deliveries |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-19 14:13 | Spec and Grove |
| | Ledgeway and Sedgeway | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-19 14:13 | Turn on water services |
| 99 | Barnum Rd | Dig-Safe - Water | rlinde@ayer.ma.us | 2016-4-19 14:13 | Multiple DIGSAFE markouts |
| | | | | | Multiple DIGSAFE markouts |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-19 14:13 | Attend pre construction meeting |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-19 14:14 | Daily rounds |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-19 14:13 | Daily lab |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-19 14:13 | Prepare for and attend Foremans Meeting |
| | | | | | Prepare for and attend Foremans meeting |

| | | | | | | |
|----|------------------------|-----------------------|-----------------------|-----------------|---|--|
| 53 | Main St | Dig-Safe - Water | tlahntinen@ayer.ma.us | 2016-4-19 06:21 | <p>TIME..13:33</p> <p>DATE..04/18/2016</p> <p>REQUEST NO...20161602174</p> <p>STATE.....MASSACHUSETTS</p> <p>MUNICIPALITY..AYER</p> <p>STREET...MAIN ST</p> <p>NEAREST CROSS STREET 1..WEST ST</p> <p>NEAREST CROSS STREET 2..STATE RTE 2A</p> <p>BEST ACCESS TO THE ROW IS ACROSS FROM WEST ST ON MAIN ST, NEAR THE KEOLIS COMMUTER LINE AT THE FIRST TRACK YOU COME TO ALL THE WAY TO THE STATE RTE 2A OVERPASS (BOTH ENDS ARE MARKED)</p> <p>-----</p> <p>..</p> <p>NATURE OF WORK...REPLACING A SECTION OF RR TRACK</p> | |
| 53 | Main St | Dig-Safe - Highway | tlahntinen@ayer.ma.us | 2016-4-19 12:23 | <p>TIME..13:33</p> <p>DATE..04/18/2016</p> <p>REQUEST NO...20161602174</p> <p>STATE.....MASSACHUSETTS</p> <p>MUNICIPALITY..AYER</p> <p>STREET...MAIN ST</p> <p>NEAREST CROSS STREET 1..WEST ST</p> <p>NEAREST CROSS STREET 2..STATE RTE 2A</p> <p>BEST ACCESS TO THE ROW IS ACROSS FROM WEST ST ON MAIN ST, NEAR THE KEOLIS COMMUTER LINE AT THE FIRST TRACK YOU COME TO ALL THE WAY TO THE STATE RTE 2A OVERPASS (BOTH ENDS ARE MARKED)</p> <p>-----</p> <p>..</p> <p>NATURE OF WORK...REPLACING A SECTION OF RR TRACK</p> | |
| 0 | Main St | Main St Trash | djaspersen@ayer.ma.us | 2016-4-15 13:34 | | Mike F and Dave M did main Street trash & town hall and main DPW garage. |
| 0 | Old East Main & Elm St | Misc Debris Removal | djaspersen@ayer.ma.us | 2016-4-15 09:33 | | Doug picked up old TV drop off on corner. |
| 17 | W Main St | Sidewalk - Repair | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Cement Sidewalk Patch | Sidewalk Repair on the corner of Park & West Main St by Fire Station concert is failing and falling apart. Bruce Wally & Mike W did a concert sidewalk Repair they used 5 bags of concert on the repair. |
| 60 | Hill Section | Street Sweeping | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Sweeping | Mike F and Dave M are sweeping the last section on the spring 2016 sweeping list the Hill section. |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-15 14:16 | Daily lab | Daily lab |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-15 14:16 | Daily rounds | Daily rounds |
| 99 | Barnum Rd | Bact-T Sampling | rlinde@ayer.ma.us | 2016-4-15 14:16 | Bac and chlorine sampling | Bac and chlorine sampling |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-15 14:16 | Daily lab and rounds | |
| 0 | Town Crosswalks | Pavement Repair | djaspersen@ayer.ma.us | 2016-4-15 13:34 | | I am sending out Bruce and Dave M to saw cut a few pot holes in some of the crosswalks to clean them up before we start the spring crosswalk painting of them. |
| 0 | Town Roads | Pot Hole | djaspersen@ayer.ma.us | 2016-4-29 10:44 | | So we started spring road patching and winter damage driveway repairs. We patched part of Willard St in the Devens Crest area the driveway at 22 Willard holes on the East Main St & Main St & Park St & In front of the Police Station also a car Killer down by Tinys on Park and Fitchburg Rd (RT 2A) also Groton Shirley Rd and at the beginning of James Brook Rd and Central Ave by Post Office. We used 4 ton of hot mix. |

| | | | | | | |
|-----|--------------------------|--------------------------------|-----------------------|-----------------|--|--|
| | | | | | Hi Mark, Would you be able to have one of your guys take down the two Vitasoy Signs for me. (They will need a Phelps Head Screwdriver.) I will be happy to meet them over at 1 New England Way when they go out to do it, or I can pick the signs up at the DPW after the fact. I need to send the signs out to be updated. Thanks, Alicia Hersey Town of Ayer Office Community Development | |
| 1 | New England Way | Misc Signs | mwetzel@ayer.ma.us | 2016-4-19 12:23 | | |
| 95 | W Main St | Pot Hole | djaspersen@ayer.ma.us | 2016-4-28 12:55 | | We are starting are spring pot hole patching today on veriest roads around town and doing some winter driveway way repairs damaged over the plowing months by town plows. |
| | Shirley St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Mark Outs | There are 2 Mark Outs for the same company doing borings on both sides of the washed out culvert. #1507873 #1507851 |
| 9 | Myrick St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Mark Out for Home Owner | installing bigger parking area |
| | Maple St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Dig Safe Mark Out Grid | installing new ground rod pole #7 |
| 8 | Bennett's Crossing | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Dig Safe Mark Out for J & L cable | installing cable underground cable to house for cable TV |
| 9 | Mulberry | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Dig Safe Mark Out J & L Cable | installing underground cable for TV |
| | Williams St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Dig Safe Mark Out Grid | installing ground rod pole #8 |
| | Pleasant St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Dig Safe Mark Out Grid | Mark Out around pole #7 for replacement |
| 138 | Littleton Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-19 12:23 | Dig Safe Mark Out | These are all MassDot State Drains |
| 0 | Town Roads | Pot Hole | djaspersen@ayer.ma.us | 2016-4-14 11:24 | | Bruce B is getting the roller and tools ready for Thursday so we can start are spring pot hole patching we are going to start fixing some winter damage driveway repairs and move on to patching some of the bad areas streets that have the most pot holes from winter damage. |
| | Sandy Pond area | Street Sweeping | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Spring Street Sweeping | Dave M & Mike F are finishing up the Pond & Central Ave area today and heading to the Hill section to start that area. |
| 4 | Victor Dr | Roadway Ice Operations | djaspersen@ayer.ma.us | 2016-4-13 10:04 | Plowing Yard & Driveway Damage | 4 Victor Dr has yard and driveway plow damage from winter one sprinkle head has been torn up and driveway apron needs to be fixed also. Bruce is doing the yard Repair today 4\13\2016. Need to talk to home owner about sprinkler head Repair and driveway Repair. Talked to home owner 4\13\2016 We are going to saw cut apron of driveway and replace it with new hot top. |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-15 14:03 | Daily rounds | Daily rounds |
| | Spec Pond | Grounds Maintenance - Water | rlinde@ayer.ma.us | 2016-4-15 14:03 | Pull beaver dam at treatment plant | beaver dam at Spec |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-15 14:03 | Plant maint, chlorine | plant maint chlorine |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-15 14:03 | Daily lab and rounds | Daily rounds and lab |
| | Spec Pond | Grounds Maintenance - Water | rlinde@ayer.ma.us | 2016-4-15 14:03 | Regrade and repair gravel road, and drainage around well # 1A | Regrade and repair Spec |
| 25 | Brook St | Equipment Preparation | djaspersen@ayer.ma.us | 2016-4-14 11:24 | Sander Removal | Do to the rain the guys will be cleaning oiling and removal of the remaining Sanders out of the trucks today. |
| 9 | Shaker Rd | Misc Debris Removal | djaspersen@ayer.ma.us | 2016-4-13 06:44 | | Stop on Shaker Rd and picked up a bunch of trash someone tossed out of there car |
| 1 | Main St TOWN HALL | Landfill Monitoring/Inspection | mwetzel@ayer.ma.us | 2016-4-12 11:08 | Pick up old computer equipment at town hall and recycle or dispose of. Equipment is located in Great Hall conference area and is labeled. Any questions - contact Cindy Knox | |
| 10 | East St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Dig Safe Mark Out for Grid | new gas service |
| | School St & Grove St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-15 13:34 | Grid Dig Safe Mark out | new gas service |
| | Barnum Road | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-14 11:24 | There are 6 total Dig Safe Requests all from the same company for this area from Nat'l Grid | Inspection of Street gate valves |
| | West Main St & Grant Rd. | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-12 06:45 | dig safe mark out | Devens installing new sign |
| 0 | Main St | Main St Trash | djaspersen@ayer.ma.us | 2016-4-12 06:45 | | Mike F and Dave M did all of the town trash this morning Main St & Town Hall etc. |
| | Sandy Pond & Central Ave | Street Sweeping | djaspersen@ayer.ma.us | 2016-4-12 06:45 | Sweeping | Mike F and Dave M are back at spring sweeping cleanup working on Sandy Pond section and then moving on to the Central Ave area. |

| | | | | | | |
|----------|---------------------------|---------------------------------------|-----------------------|-----------------|--|--|
| 1 | Mulberry Cir | Grounds Maintenance - Water | rlinde@ayer.ma.us | 2016-4-13 13:37 | Rake and fertilize grounds at booster and plants | Rake and fertilize grounds at booster and plants |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-13 13:37 | Prepare and attend | Prepare and attend |
| 27 | Pearl St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-11 06:51 | Foremans Meeting | Foremans Meeting |
| 52 | Littleton Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-11 06:51 | dig safe Mark out | |
| 91 | Littleton Rd | Complaint/Investigation - Stormwater | djaspersen@ayer.ma.us | 2016-4-8 10:40 | Beaver Dam Problem | Going to open up Beaver Dam behind Blue Northern plus fix the easement road down to the dam We installed millings to the cart road behind the building ripped out 13 feet of the beaver Dam that was on top of the old man made block Mill Dam to get the water flowing down stream. |
| | Doug Rd / Rosewood Beav | Inspection - Wastewater | mwetzel@ayer.ma.us | 2016-4-27 08:52 | GPS locate and measure elevation of sewer manholes that are underwater. Will require boat and GPS unit. | GPS completed by Dan V and Brian C on 04/21/2016. Dan V is having GPS data loaded to GIS. Pictures and site plan with findings are posted on shared drive at S:\1-Projects\Rosewood Area Manholes |
| 5 | Mark St | Inspection - Highway | tlahinen@ayer.ma.us | 2016-4-13 08:54 | 5 Mark St - Plow tore up yard in front. | Guthrie claims plow during snow storms tore up front yard. There is plow damage and we will add some loam and seed and clean it up this week. Bruce did yard Repair with loam and seed 4\13\2016. |
| 22 | Robbins rd | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 10:02 | Dig safe, installing retaining wall, steps and drainage, left side of house | Bryan C marked the property and the street |
| 35 | Nemco way | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 10:00 | Dig Safe, new service installation from street to building | Bryan C marked the entire property and street |
| 21 | Grove st | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 09:55 | 4-7-2016 Dig safe, install fence on entire property | Bryan C marked where service comes out of house to the street and marked the sewer line in the street |
| 2 | Willow rd | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 09:53 | Dig safe, Digging 5' test pits in miscellaneous spots | Bryan C marked from the establishment to the street |
| 1 | Victor dr | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 09:50 | Dig safe, gas leak repair | Bryan C marked the street and the property |
| 10 | High st | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-8 06:38 | Dig safe, gas leak repair | Bryan C marked the street and the property |
| 8 | Moore dr | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-8 06:38 | Dig safe, gas leak repair | Bryan C marked the street and the property |
| 21 | Loon hill rd | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 09:46 | Dig safe, install invisible fence on entire property | Bryan C marked from the house to the street and the sewer line in the street |
| 3 | Patricia drive | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 09:43 | Emergency dig safe, repair broken sewer line | Bryan C marked the street and the property |
| | Ayer gun club access road | Dig-Safe - Wastewater | rhudson@ayer.ma.us | 2016-4-8 06:36 | Dig safe, replace structures | Bryan C marked no sewer at the entrance of the access road going into the power lines |
| | Groton school road | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 09:38 | Dig safe, replace structures along power lines | Bryan C marked, no sewer near the access gate to the power lines |
| 27 | High St | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 09:35 | Dig safe, installing new gas service | Bryan C marked the street and where the homeowners service exits the house and enters the street |
| 4-6-2016 | 38 Central Ave | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-7 09:33 | Dig safe, replace utility pole #10 | Bryan C marked the street and where them homeowners service comes into the street |
| 35 | Nemco Way | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 08:06 | Grid | installing new gas service |
| 22 | Willard St | Service Req - Investigation - Highway | mwetzel@ayer.ma.us | 2016-4-15 13:34 | Woman called about the berm at the end of her driveway. She said we had placed it 4 or 5 years ago and it had been damaged by a plow this winter and also was getting flattened so it was not effective. | Found that there is a piece missing from the up side of the driveway that we need to replace. |
| 25 | Brook St | Catch Basin Clean Out | djaspersen@ayer.ma.us | 2016-4-7 10:46 | Cleaning off basins | Bruce & Dave M will be out cleaning off and checking storm water catch basins do to heavy rain coming in later today. |
| 25 | Brook St | Misc Special Event | djaspersen@ayer.ma.us | 2016-4-7 10:46 | | Mike F Go's for his CDL today he and Mike W are heading to the city at 10:30am this morning for driving test. |
| | East Main St | Misc Signs | djaspersen@ayer.ma.us | 2016-4-7 10:46 | Sign removal | East Main St by Court House we are removing 4 No Parking Signs they are no longer need off of East Main by Court House parking lot. |
| 27 | High St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 07:11 | Grid | install new gas service |
| 10 | High St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 07:11 | Grid | gas leak repair |
| 8 | Moore Dr | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 07:11 | Grid | gas leak repair |
| | Groton Shirley Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 07:27 | Verizon | replacing poles and ground rods near house #88 |
| | West Main St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 07:11 | Version tele pole | installing ground rod |
| 0 | West Main \ Green Mile | Dead Animal Removal | djaspersen@ayer.ma.us | 2016-4-7 10:46 | | Doug and Wally removed dead raccoon from roadway |
| 99 | Barnum Rd | Bact-T Sampling | rlinde@ayer.ma.us | 2016-4-7 14:20 | Meter installs and reads | Meter installs and reads |
| 99 | Barnum Rd | Dig-Safe - Water | rlinde@ayer.ma.us | 2016-4-7 14:20 | DIGSAFE townwide | DIGSAFE townwide |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-7 14:20 | Daily rounds | Daily rounds |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-7 14:20 | Daily Lab | Daily lab |
| 1 | Wagon Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-7 14:20 | Set up Forest Spec Pond | Set up Forest Spec Pond |
| | Washington Street by Gro | Culvert/Swale Cleaning | djaspersen@ayer.ma.us | 2016-4-6 10:21 | Storm water wash out problem | Cleaning out 2 gutter drains we have a run off problem behind sidewalk and banking washing out under minding sidewalk behind guardrail need to cut out sidewalk add fill and repair sidewalk after need to keep an eye on this area to make sure we don't have feather problems with this. |
| 31 | Grove St | Pipes & Structures Work | djaspersen@ayer.ma.us | 2016-4-7 10:46 | Drainage outfall cleanup | Heading over to 31 Grove St to install Rip Rap stone at the storm water drainage out fall as requested we do by Mark |
| 21 | Loon Hill Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 06:34 | Install Fence | |
| 1 | Victor Dr | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 06:34 | Grid Gas Leak Repair | Digging Street to house |

| | | | | | | |
|-----|--|-----------------------------|-----------------------|-----------------|---|---|
| 3 | Patricia Dr | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-5 10:01 | Emergency Dig Safe | R&R broken sewer house line to Street not digging into road coming out 17ft from house. |
| | | | | | | We did most of the storm cleanup right after the storm sidewalks etc. Doug and Wally came in early to check the main roads and bus routes and schools to make sure everything was set we had to hit and cleanup a few areas and finish cleaning up the DPW yard. |
| 95 | W Main St | Roadway Ice Operations | djaspersen@ayer.ma.us | 2016-4-7 06:34 | After storm cleanup | Mike F did Main St and Town Hall trash Monday before snow storm. |
| 95 | W Main St | Main St Trash | djaspersen@ayer.ma.us | 2016-4-7 06:34 | | |
| 95 | W Main St | Roadway Ice Operations | djaspersen@ayer.ma.us | 2016-4-7 06:34 | Snow amounts | Morning News said we got just over 5 inches |
| 95 | W Main St | Equipment Preparation | djaspersen@ayer.ma.us | 2016-4-13 08:54 | Sander Cleaning Washing Trucks | Guys are unloading sander washing and cleaning trucks after the small snow storm |
| | Townwide | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:10 | Read meters | Read meters |
| | Municipal Bldgs | Inspection - Water | rlinde@ayer.ma.us | 2016-4-5 14:09 | Test backflows | |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:09 | Daily Lab | Daily lab |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:14 | Daily lab | |
| | end of Nemco Spec sections | Water Quality Sampling | rlinde@ayer.ma.us | 2016-4-5 14:09 | Titration | Titration |
| | | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:15 | | |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:09 | Daily rounds | Daily rounds |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:09 | Daily lab | Daily lab |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:09 | plant maint. | plant maint. Service and repair turbidity meter and lines, repair chlorine lines |
| 99 | Barnum Rd | Grounds Maintenance - Water | rlinde@ayer.ma.us | 2016-4-5 14:09 | Small engine service and repair | small engine service and repair |
| | end of Nemco Way Spec | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:09 | Plant Maint | Plant maint. clean and service CL 17 and turbidity meter |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-5 14:12 | Admin and Prepare for and attend Foremans meeting | |
| | Snake Hill Rd - NGrid Row | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 06:34 | mark out Dig safe | |
| | Washington St & Groton H | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-8 07:56 | mark out Dig safe | removing contaminated soil |
| 2 | Willow Rd | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 06:34 | mark out Dig safe | digging test pits |
| 38 | Central Ave Pole #10 | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 06:34 | mark out Dig safe | |
| | Groton School Rd -NGrid R | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 06:34 | Mark out Dig Safe | |
| 27 | High St | Dig-Safe - Highway | djaspersen@ayer.ma.us | 2016-4-7 06:34 | mark out Dig safe | |
| | Thursday afternoon we re: Jetting/Cleaning | | rhudson@ayer.ma.us | 2016-4-4 08:56 | | |
| | | | | | | |
| | | | | | | |
| | Wendy's, Nashoba Club, T | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-8 06:37 | 3-30-2016 Bryan C did grease trap inspections at the following locations, Wendy's, Nashoba Club, Tiny's, Shop N Save, Sevens Pizza, Dan's Place, Woo Jung, Parthenon and Subway. No issues with any location. | |
| | | | | | | |
| | | | | | | |
| | Taco Bell, McDonalds, Laz | Inspection - Wastewater | rhudson@ayer.ma.us | 2016-4-8 06:34 | 3-28-2016 Bryan C and Ken H did grease trap inspections at the following locations, Taco Bell, McDonalds, Lazy Mary's and the Mango Grill. No issues with any location. | |
| | | | | | | |
| | | | | | | |
| 180 | Washington St | Roadway Ice Operations | djaspersen@ayer.ma.us | 2016-4-7 06:34 | Small snow storm | Going to be out salting roads today we have light snow all day with a couple heavier bands coming in here and there . |
| 151 | oak ridge drive | Dig-Safe - Highway | wwood@ayer.ma.us | 2016-4-1 11:20 | | |
| 173 | Willard street | Dig-Safe - Highway | wwood@ayer.ma.us | 2016-4-1 11:20 | | |
| 145 | old farm way | Dig-Safe - Highway | wwood@ayer.ma.us | 2016-4-1 11:20 | | |
| 100 | E Main St | Replace Sign | djaspersen@ayer.ma.us | 2016-4-1 11:23 | Install new sign | Replace School Bus Stop Sign at 95 E main Bruce & Doug put new breakaway and post also |
| | One Way Harvard Rd were | Replace Sign | djaspersen@ayer.ma.us | 2016-4-1 11:21 | New 25 Mile an Hour Speed Sign | Install a new 25 Mile an hour sign prep request of Ayer PD |
| 25 | Brook St | Equipment Preparation | djaspersen@ayer.ma.us | 2016-4-1 13:51 | Snow & Ice Storm prep | The guys are reinstalling sander in Truck#13 for possible small snow storm Monday into Tuesday plus putting on small truck plows in case of storm. |
| 25 | Brook St | Street Sweeping | djaspersen@ayer.ma.us | 2016-4-1 13:51 | Street Sweeping Spring Cleanup. 2016 | Mike F and Dave M are sweeping another section the Pringy Hill area today the completed Devens Crest area and Benntts Crossing on Wednesday of this week. |
| | Main St Friday Sweeping | Street Sweeping | djaspersen@ayer.ma.us | 2016-4-1 09:30 | | Main St Sweeping Dave M took care of it first thing this morning |
| 25 | Brook St | Misc Vehicle Work | bburns@ayer.ma.us | 2016-4-1 13:51 | Possible storm prep | Getting plows on small trucks and putting sander back in H13 for possible weekend storm |
| 46 | and 173 Willard St | Water Service Work | rlinde@ayer.ma.us | 2016-4-1 14:41 | Emergency DIGSAFES | Emergency DIGSAFES |
| 99 | Barnum Rd | Water Service Work | rlinde@ayer.ma.us | 2016-4-1 14:37 | Test town back flow devices | Test town backflow devices |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-1 14:35 | Plant maint and repair injection quill KOH clean up | Plant maint |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-1 14:35 | Daily lab | Daily lab |
| 99 | Barnum Rd | Misc Water Work Order | rlinde@ayer.ma.us | 2016-4-1 14:35 | Daily rounds | Daily rounds |
| 18 | Main St | Street Sweeping | djaspersen@ayer.ma.us | 2016-4-1 13:51 | Section Sweeping | Mike F and Dave M are finishing up the East End and heading over to Devens Crest area after that. |
| | | | | | | |
| | | | | | | |
| 17 | Main Street | Sidewalk - Repair | djaspersen@ayer.ma.us | 2016-4-7 06:34 | Temp Sidewalk Repair | Need to do a temp sidewalk Repair on the Main Street sidewalk in between Stella's Flower & The Cottage. We are going to install some Hydro Cement on the 2 edges of part of the sidewalk that has been lifted up by a Main Street tree roots until we come up with something more permanent fix. Before and after photos are along with report. |

| | | | | | | |
|----------|---|----------------------------|-----------------------|-----------------|---|--|
| 25 | Sandy Pond & Central Ave Pot Hole | | djaspersen@ayer.ma.us | 2016-4-6 09:22 | pot hole patching | Bruce & Mike W patched pot holes on Sandy Pond Rd & Central Ave with Pug Mill |
| | Wright Rd Dig-Safe - Highway | | djaspersen@ayer.ma.us | 2016-4-11 06:51 | install new yard light pole | |
| | MacPherson Rd Devens M Dig-Safe - Highway | | djaspersen@ayer.ma.us | 2016-4-11 06:51 | Demo Work | Demo & Remove all old UTIL |
| | blower building | Misc Wastewater Work Order | rhudson@ayer.ma.us | 2016-4-8 06:33 | | John S. serviced the four blowers on 3/24/2016 by greasing,changing the oils and replaced all the belts for each blower (the belts were dry rotted) |
| | | | | | Bryan C. and Dave N. jetted all of Grove St. and Elm St. on 3/22/2016 they used about 3,000 gallons of water and jetted 1,800 feet of streets | |
| 0 | Grove St. and Elm St. | Jetting/Cleaning | rhudson@ayer.ma.us | 2016-4-8 06:33 | | |
| 0 | Main pump station | Daily Inspection | rhudson@ayer.ma.us | 2016-4-11 01:49 | | station running good |
| 0 | Central Ave pump station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-11 09:44 | | pumps #2 & #3 are running good |
| | | | | | Court House Crosswalk Sign Problems | Need to know what plan Ayer Police comes up with for me to relocation of crosswalk sign before I can take care of this. |
| 32 | E Main St | Misc Signs | djaspersen@ayer.ma.us | 2016-4-1 13:51 | | |
| | Oak Ridge Dr 147 | Dig-Safe - Wastewater | rhudson@ayer.ma.us | 2016-4-8 06:32 | | |
| | | | | | Friday 3-11-2016, Dave Nelson Jr. and Bryan Copeland, jetted the McDonalds side of Sandy Pond Rd as a follow up to the sewer plug called in last Friday. Last Friday when they unplugged the street they observed a large amount of grit in the line and went b | |
| | McDonalds side of Sandy | Jetting/Cleaning | rhudson@ayer.ma.us | 2016-4-8 06:31 | | |
| | | | | | Thursday 3-10-2016, John Loomer and Bryan Copeland, jetted from the Cains and McDonalds interceptor near the rotary over to the Marshall street easement. They did approximately 1500ft and used approximately 4900gals. of water. They found a lot of grease a | |
| | Cains and McDonalds inte | Jetting/Cleaning | rhudson@ayer.ma.us | 2016-4-8 06:29 | | |
| 0 | Oakridge #2 pump station | Check Controls/Alarms | rhudson@ayer.ma.us | 2016-4-11 01:46 | | pumps running good |
| 0 | Oakridge #2 pump station | Check Controls/Alarms | rhudson@ayer.ma.us | 2016-4-11 01:46 | | pumps working good |
| 0 | Main pump station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-1 07:13 | | pumps are running good |
| 0 | Central Ave pump station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-11 09:44 | | pumps #2 & #3 running good |
| 0 | Central Ave pump station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-11 09:44 | | pumps #2 & #3 are running good |
| 0 | Central Ave pump station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-11 09:44 | | pumps #2 & #3 are running good |
| 0 | Main pump station | Daily Inspection | rhudson@ayer.ma.us | 2016-4-11 01:50 | | station running good |
| 0 | Central Ave pump station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-11 09:44 | | pump #2 & #3 running good |
| 3-3-2016 | Dig safes completed= 50 S Inspection - Wastewater | | rhudson@ayer.ma.us | 2016-4-8 06:28 | | |
| 0 | Central Ave pump station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-11 09:44 | | VFD #1 is still not replaced still running on #2 and #3 pumps |
| 0 | Main pump station | Pump Maintenance | rhudson@ayer.ma.us | 2016-4-11 01:51 | | John S. is working on the pressure gauges for our pumps and Devin's pumps so they will read correctly. |
| 0 | Central Ave pump station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-11 09:44 | | VFD #1 is still not replaced besides that pumps #2 & #3 are running good |
| 6 | Winterberry Ln | Check Controls/Alarms | rhudson@ayer.ma.us | 2016-4-11 01:47 | | |
| 0 | Main pumping station | Daily Inspection | rhudson@ayer.ma.us | 2016-4-11 01:49 | Still have on and off again communication failure | |
| | | | | | | We've still been having communication failures in Main and Central ave pump station since 2/17/2016 where it would come in and out at all hours. We have called Verizon (and total hours of on the phone with them has been 12 hours) we had techs out testing lines and saying they have good strong signals. Rick and Dave have also called Jason Roach of NSC and received his advise on what could be wrong and he's adamant about its the phone lines. We have changed the modem at Main pump station and still having the same problem. Verizon came out and tested the lines but they tested the lines to Devin's and not the Main and Central ave lines. |
| 0 | Main pumping station | Building Maintenance | rhudson@ayer.ma.us | 2016-4-11 01:49 | | |