



Working Together to Identify and Implement the Optimal Groundwater Treatment Solution for PFAS

Mark Wetzel, P.E. (*Town of Ayer, MA*)

Ji Im, P.E. (*CDM Smith*)

June 11, 2019, 2:00 pm

Presentation Outline


1. Background
2. PFAS Discovery and Response
3. Grove Pond WTP
4. Spectacle Pond WTP
5. Alternative Water Supply
6. Summary



Community Background

- Located in central Massachusetts
- 9.5 square miles
- Population 7,600
- Dept. of Public Works – water, wastewater, stormwater, roads & bridges, solid waste, Snow plowing, street lights

Massachusetts



Town of Ayer, Massachusetts



Railroad Town



Army Town



Movie Town?

Ayer's Water Supply

- 5 wells – 3 at Grove Pond, 2 at Spectacle Pond
- Two Greensand WTPs
- Two distribution storage tanks
- Demand: 1.4 MGD (average) & 2.7 MGD (maximum)
- 60 % of water use is commercial / industrial
- Total supply yield – 3.7 MGD




Ayer's Water Supply Challenges

- Very high iron (2.5 to 3.4 ppm)
 - *Secondary MCL 0.3 ppm*
- Very high manganese (0.85 to 5.66 ppm)
 - *Secondary MCL – 0.05 ppm*
- Arsenic – 0.007 to 0.069 ppm
 - *MCL – 0.01 ppm*
- Lead and Copper Rule
- Total Coliform Rule
- Aging infrastructure




PFAS Discovery & Response

- Not required to sample for PFAS under UCMR3
- Sept. 2016: due to proximity to Fort Devens, MassDEP required Ayer to test Grove Pond Wells for PFOA and PFOS
- All wells had PFAS - GP Well 8 was over the 70 ppt EPA Health Advisory Level
- Contamination from past Ft. Devens activities
- Army Corps of Engineers is investigating extent of groundwater contamination



Discovery of PFAS vs. MassDEP Guidance Level



PFAS Discovery & Response

- Sampled Spectacle Pond Wells 1A and 2A - both had PFAS levels in 20s and 30s
- Since HA was 70 ppt, we did not start to address this supply at the time
- Also sampled levels in distribution storage tanks to evaluate system levels




Working with MassDEP through 2018 Issues

- Worked closely with MassDEP (and still do)
- Changed SCADA controls so GP Well 8 would only run with Wells 6 & 7 to blend to below 70 ppt
- Dirty water complaints due to water chemistry changes (and stress on WTP)
- Positive Total Coliform in August
- GP Well 6 “plugging” – required redevelopment
- Constructed interconnection with Devens – but they have PFAS also!



DPW Actions 2018

- Stopped using Well 8 in late February
- DPW issued public notification on March 29
- Evaluated supply alternatives
 - Interconnections, temporary treatment, use of emergency wells
- Completed preliminary treatment study
- Began bench scale testing & final design
- Re-activated Grove Pond Well 1
 - Fe 2.6mg/l, Mn 4.9mg/l
- Constructed Spec Pond Well 2 replacement
 - Tested at 900 gpm
- Cleaned and redeveloped Spec Pond Well 1A






Ji Im, P.E.

PFAS - Emerging Contaminant



- Per- and Poly-FluoroAlkySubstances (PFAS)



- PerFluoroOctanoic Acid (PFOA)



- PerFluoroOctaneSulfonic Acid (PFOS)




State Regulatory Environment

- Overall downward trend of health advisory levels & standards nationally
- Public push for more stringent levels in drinking water



Source: National Telegraph



MassDEP Health Advisory Levels


- Massachusetts Department of Environmental Protection (MassDEP) health advisory level issued in June 2018
- 70 ppt in drinking water for: PFOA, PFOS, PFHxS, PFNA, and PFHpA, individually or combined– *TO BE LOWERED TO 20 PPT*
- MassDEP has begun the process of developing a PFAS MCL- Process may be completed by next spring

| PFAAs | C4 | C5 | C6 | C7 | C8 | C9 | C10 | C11 | C12 |
|--------------|------|-------|-------|-------|------|------|------|-------|-------|
| Carboxylates | PFBA | PFPeA | PFHxA | PFHpA | PFOA | PFNA | PFDA | PFUnA | PFDoA |
| Sulfonates | PFBS | PFPeS | PFHxS | PFHpS | PFOS | PFNS | PFDS | PFUnS | PFDoS |

Short-Chain PFAS

Long Chain PFAS


Grove Pond Water Treatment Plant (WTP)




- Grove Pond WTP
 - 2 million gallons per day (mgd) facility
- Three groundwater wells
- Existing treatment plant:
 - Greensand filtration for iron and manganese removal
 - Chemical treatment (e.g. pre-oxidation, disinfection, pH adjustment)




PFAS Treatment



Granular Activated
Carbon (GAC)



Anion Exchange
(AIX)




Membrane

- ✓ Water quality (e.g., low organic)
- ✓ Town's familiarity with pressure vessels
- ✓ No liquid waste stream of concern
- ✓ Comparatively lower cost (vs. membrane)

Bench Scale Testing: GAC Versus AIX

- PFAS treatment process to be placed downstream of the existing greensand filters (post iron & manganese removal)



Bench Scale Testing: GAC versus AIX

Bench-scale testing to investigate:


- Two (2) GAC media
 - coal-based vs. coconut-based
- Two (2) AIX resin media
 - gel vs. macroporous
- GAC followed by AIX
- Impact of chlorine residual on AIX removal of PFAS



*CDM Smith's Bellevue
Laboratory, Washington*




GAC




- Data in C/Co = final conc. / initial conc. = removal efficiency (lower C/Co = better removal)
- The two GAC products behaved similarly
- Better removal efficiency with sulfonates than carboxylates
- Better removal efficiency with longer chain compounds

GAC




- Data in C/Co = final conc. / initial conc. = removal efficiency (lower C/Co = better removal)
- The two GAC products behaved similarly
- Better removal efficiency with sulfonates than carboxylates
- Better removal efficiency with longer chain compounds

AIX




- Resin 2 is specific for PFAS removal
- Significant differences in PFAS removal efficiency between the two resins tested
- Harder to remove shorter chain carboxylates

Effects of Pre-GAC Treatment




- Marginal improvement in AIX effectiveness by GAC pre-treatment upstream.

TOC = ~0.5 mg/L



Effects of Residual Chlorine Removal on AIX



- Chlorine residual in influent (0.2-0.5 mg/L) from the existing greensand filters
- Dechlorination with calcium thiosulfate resulted in enhanced PFAS removal efficiency

Chloride to Sulfate Mass Ratio (CSMR)



- Increased CSMR is associated with galvanic corrosion of lead solder connected to copper pipes
 - Raw water: **Average sulfate = 16.6 mg/L**
 - After 1,000 BVs:
 - Resin 1: sulfate = 6.4 mg/L
 - Resin 2: sulfate = **16.6 mg/L**
 - After ~30,000 BVs:
 - Both Resin 1 and Resin 2 at the raw water sulfate level

$$CSMR = \frac{\text{Chloride}}{\text{Sulfate}}$$

| Scenario | CSMR |
|--------------------------|------|
| Current | 7.7 |
| After 1000 BVs – Resin 1 | 20 |
| After 1000 BVs – Resin 2 | 7.7 |


New PFAS Treatment Facilities

- AIX for PFAS Removal
- Calcium thiosulfate for dechlorination & bag filters prior to IX
- Zinc orthophosphate for improved corrosion control





Construction Cost: \$3.1M



Spectacle Pond WTP

- MassDEP's health advisory of 20 ppt anticipated
- Testing and design of AIX facility
- Beginning preliminary design process to evaluate process, costs, schedules
- Need to vote funding at Fall Town Meeting
- Working with MassDEP Waste Site Clean-up to identify responsible party (not Ft. Devens)



Point of Use (POU) Filter Testing

- POU home faucet filter system testing
 - At WTP vs. in distribution system
 - Cold water vs. hot water
 - Continuous use vs. normal residential use
- Monitoring PFAS, volume, and various water quality parameters
- Preliminary cold water testing results showed significant impact on capacity with chlorine residual





Mark Wetzel, P.E.

Where We Are Now

- April 2019 – sent out second public notice
- Installing temporary GAC treatment for GP Well 8
- Working with US Army to fund treatment and O&M (thank you EPA Region 1 and Senator Warren)
- Outdoor water ban (not popular)
- Continue to provide regular updates to the town officials, website and Facebook posts
- Personal response to residents questions
- Ayer cannot meet 20 ppt without treatment at Spec Pond Wellfield




Takeaways & Summary



Water suppliers need to be provided with public talking points



Need a better understanding of short- and long-term health effects



State PFAS Response Team needed instead of case-by-case response, and regulatory “moving target” provides challenges to implementing solutions.



PFAS actions may create other water quality issues




Many considerations factor into PFAS treatment selection & placement



Pre-design study is critical in determining treatment selection and compatibility with the existing treatment

Acknowledgement

- Town of Ayer DPW
 - Dan Van Schalkwyk, P.E.
- MassDEP Central Region
- CDM Smith team
 - Lisa Gove, P.E., BCEE
 - Alan LeBlanc, P.E., BCEE
 - Charles Schaefer, Ph.D.





Contact us!

Ji Im, P.E.

603-222-8356

imj@cdmsmith.com

@Jihyon_Im

Mark Wetzel, P.E.

978-772-8240

mwetzel@ayer.ma.us


@dpwsupt



Water
Partnership
with **CDM
Smith**

Learn more about the water partnership at
cdmsmith.com/water and [@CDMSmith](https://twitter.com/CDMSmith)

Validating Use of RSSCTs for PFAAs on AIX



- Datapoints = unground resin testing
- Line = scaled from ground resin data

Rapid Small Scale Column Testing (RSSCT)

$$\frac{EBCT_G}{EBCT_U} = \left(\frac{d_G}{d_U} \right)^2$$

*constant diffusivity
for scaling*

Transport Eqn. (Thomas Model):

$$\ln \left[\frac{C_0}{C} - 1 \right] = \left(\frac{kmq_0}{Q} \right) - [EBCT]kC_0BV$$

*where q₀ scales with r-0.5
to account for surface sorption*

- RSSCT, assuming constant diffusivity and coupled with the Thomas model, were effective for scaling PFAS removal with ground AIX resin.
- Demonstrated that RSSCT can be used to effectively evaluate PFAA uptake on AIX in low TOC water